

44 East Mifflin Handbook

Indoor Air Quality

Indoor air quality is an issue important to everyone. Outside fresh air is supplied from a central “fresh air handler” to the return air plenum above the acoustical ceiling and, in some cases, to the individual heat pumps in your suite. The fans and ducts have been designed with the purpose of having the amount of fresh air being delivered to each suite exceed what is required by current building codes. If you have any concerns about the quality of air in your space, please contact the ULI office to discuss your concerns.